

**Translation of Testing Report  
from Marathi language into English language**

Sample No. -Pvt/Bact/64/2022-23

OFFICE OF SENIOR GEOLOGIST,  
UNDER GROUNDWATER SURVEYS AND DEVELOPMENT AGENCY  
DISTRICT WATER TESTING LAB, BHANDARA

Behind Officer Club, Kasturba Gandhi Ward, Bhandara

Phone No.

E-mail - www.distlabbandara@gmail.com

D.L./A.B./T.R./O.N.64/2022-23

Date - 23.01.2023

To,

Dream Dale Public School, Bhandara

Subject :- Regarding Anti Bacterial Testing Report

As per above cited subject, it is to inform you that, you have brought Anti Bacterial sample on 19/01/2023 of Dream Dale Public School, Bhandara for water testing at District Lab, Bhandara. Said sample is tested and report is given alongwith this report.

Note : In future, blitching should be done correctly while using water for drinking.

Enclosure :- Anti Bacterial Testing Report

Sd/-

Senior Geologist

For Groundwater Surveys and Development Agency,

Bhandara

**TRUE COPY**

**R. K. SAXENA  
NOTARY  
Regd. No. 979  
BHANDARA.(M.S.)**



**Translation of Testing Report  
from Marathi language into English language**

OFFICE OF SENIOR GEOLOGIST,  
UNDER GROUNDWATER SURVEYS AND DEVELOPMENT AGENCY  
DISTRICT WATER TESTING LAB, BHANDARA

Behind Officer Club, Kasturba Gandhi Ward, Bhandara

Phone No.

E-mail – [www.distlabbandara@gmail.com](mailto:www.distlabbandara@gmail.com)

Name of Lab – District Lab Bhandara

Dtd. 23.01.2023

Tahsil – Bhandara

District – Bhandara

Date of Sample Received- 19/01/2023

Sr. No. 1	Name of Locality	Source Place	Source Type	Date of Testing of Water Sample	Conclusion of Testing Proper/ Inproper	Improper for which part & its mesure	
						Koli	Thermo
1	Bhandara	Dream Dale School	R.O.	19/01/2023	Proper	0	0



Sd/-

Anti Bacterial Specialist  
District Lab Bhandara

Sd/-


Senior Geologist  
For Groundwater Surveys and Development Agency,  
Bhandara

**TRUE COPY**

26/3/2023  
**R. K. SAXENA  
NOTARY  
Regd. No. 979  
BHANDARA.(M.S.)**



**CANCELLED CANCELLED CANCELLED**



---

**Certificate :- This is to certify that, the contents of this translation i.e. Marathi language to English language are true to the best of my knowledge and same are correct. Hence, this certificate.**




**C.K. Tarare**

**Bhandara - 441 904 (M.S.)**

---

*Certificate :- This is to certify that, I have verified the translation made by Mr. C.K. Tarare, Steno, Bhandara (M.S.) from original documents which is into Marathi and found that it is same. Hence, this certificate.*



**R. K. Saxena**

**Notary Public**

**Bhandara - 441 904 (M.S.)**

---

**R. K. SAXENA**

**NOTARY**

**Regd. No. 979**

**BHANDARA.(M.S.)**

---

**Certificate :-** This is to certify that, the contents of this translation i.e. Marathi language to English language are true to the best of my knowledge and same are correct. Hence, this certificate.



**C.K. Tarare**

**Bhandara - 441 904 (M.S.)**

---

*Certificate :- This is to certify that, I have verified the translation made by Mr. C.K. Tarare, Steno, Bhandara (M.S.) from original documents which is into Marathi and found that it is same. Hence, this certificate.*



**R. K. Saxena**

**Notary Public**

**Bhandara - 441 904 (M.S.)**

**R. K. SAXENA**

**NOTARY**

**Regd. No. 979**

**BHANDARA.(M.S.)**

Sample No.-Pvt/Bact/ 64 /2022-23

वरिष्ठ भूवैज्ञानिक यांचे कार्यालय  
भूजल सर्वेक्षण आणि विकास यंत्रणा, भंडारा  
अंतर्गत

## जिल्हा पाणी तपासणी प्रयोगशाळा, भंडारा

ऑफिस क्लबच्यामागे, कस्तुरबा गांधी वार्ड, भंडारा

दुरध्वनी क्र.

ईमेल -www.distlabhandara@gmail.com

जि.प्र.शा./अनु.जै./त.अ./जा.क्र./ 64 | 2022-23

दिनांक-२३.०१.२०२३

प्रती


ड्रीम डेल पब्लिक स्कुल भंडारा

विषय - अनुजैविक तपासणी अहवाल देण्याबाबत

उपरोक्त विषयाच्या अनुषंगाने आपणास सुचित करण्यात येते कि आपण दिनांक १९ /०१/२०२३ ला ड्रीम डेल पब्लिक स्कुल भंडारा चे अनुजैविक पाणी नमुना तपासणीसाठी जिल्हा प्रयोगशाळा भंडारा येथे आणून दिले. सदर नमुन्याची तपासणी झाली असून त्याचा तपासणी अहवाल या पत्रासोबत देत आहे.

टिप :- भविष्यात पाणी पिण्यास वापरतांना योग्यप्रकारे ब्लिचिंग करण्यात यावे

सहपत्र:- अणुजैविक तपासणी अहवाल

  
वरिष्ठ भूवैज्ञानिक  
भूजल सर्वेक्षण आणि विकास यंत्रणा  
भंडारा क.रि.ता.



वरिष्ठ भूवैज्ञानिक यांचे कार्यालय  
भूजल सर्वेक्षण आणि विकास यंत्रणा, भंडारा  
अंतर्गत

## जिल्हा पाणी तपासणी प्रयोगशाळा, भंडारा

ऑफिस क्लबच्यामागे, कस्तुरबा गांधी वार्ड, भंडारा

ईमेल - www.distlabbandara@gmail.com

दुरध्वनी क्र.

प्रयोगशाळेचे नाव - जिल्हा प्रयोगशाळा भंडारा

दि. २३.०१.२०२३

तालुका - भंडारा

जिल्हा - भंडारा

नमुने प्राप्त झाल्याचे दिनांक - १९/०१/२०२३

अ. क्र.	वाडी/वस्तीचे नाव	स्रोताचे स्थळ	स्रोताचा प्रकार	पाणी नमुने तपासल्याचा दिनांक	तपासणी निष्कर्ष (योग्य/अयोग्य)	कोणत्या घटकासाठी अयोग्य आहे व त्याचे प्रमाण	
						कोली.	थर्मो.
१	भंडारा	ड्रीम डेल पब्लिक स्कुल भंडारा	आर.ओ.	१९/०१/२०२३	योग्य	०	०

अणुजैविक तज्ञ  
जिल्हा प्रयोगशाळा भंडारा

सहाय्यक/ कमिष्ठ भूवैज्ञानिक  
भूजल सर्वेक्षण आणि विकास यंत्रणा,  
भंडारा

- टिप - १) वरील अहवाल हा प्रयोगशाळेत प्राप्त झालेल्या पाणी नमुन्याशी संबंधित आहे.  
२) भविष्यात पाणी पिण्यास वापरतांना योग्य प्रकारे ब्लीचिंग करण्यात यावे.



Certificate no-TC9620

**District Water Testing Laboratory**  
**Groundwater Surveys and Development Agency**  
**Senior Geologist Office, Bhandara**  
**TEST REPORT (DWTL/SG/BHN/FR/06)**



DWTL/GSDA/ BHN/ 05 /01/ 2023

date-27.01.2023

**Parameters under NABL Accreditation Scope**

<b>Issued TO- Dream Dale Public School, Sindhi colony road, Bhandara</b>		<b>Sample Inward No. DWTL/GSDA/BHN/05/01/2023</b> <b>Inward Date : 19.01.2023</b>		<b>Analysis Start :23.01.2023</b> <b>Analysis End : 23.01.2023</b> <b>Sample Category : Water</b>	
<b>Sample WATER</b>	<b>Sample Source: See page 3</b>	<b>Sample Particulars / Details : See page 3</b>		<b>Quantity Received : 01 Litre</b>	
<b>Sample collected by- S. Bhaskar</b>		<b>Samplig Date- 19.01.2023</b> <b>Sampling Time 1.00 pm</b>	<b>Environmetal condition</b> <b>Temp - 25.1</b> <b>Humidity-65%</b>	<b>Sampling Location- See page -3</b>	

**TEST RESULTS**

S. No	Test Parameter	Measureme nt Unit	Requirement as per IS10500 : 2012 (Drinking Water Specifications)		Test Result	
			Desirable Limit	Permissible Limit	S1	S2
1.	pH		6.5 TO 8.5	No Relaxation	7.19	
2.	Electrical Conductivity	uS/cm	-	-	461	
3.	TDS	mg/L	500	2000	300	
4.	Total Hardness	mg/L	200	600	160	
5.	Fluoride	mg/L	1	1.5	0.326	
6.	Nitrate	mg/L	45	-	7.339	
7.	Iron	mg/L	0.3	-	0.091	

Reviewed By

*[Signature]*  
Chemist

District lab Bhandara

Authorised By

*[Signature]*

(Junior Geologist)



Certificate no-TC9620

**District Water Testing Laboratory**  
**Groundwater Surveys and Development Agency**  
**Senior Geologist Office, Bhandara**  
**TEST REPORT (DWTL/SG/BHN/FR/06)**



**Parameters Not under NABL Accreditation Scope**

8.	Colour*	-	-	-	--	Agriable
9.	Odour*	-	-	-	Not Specific	Not Specific
10.	Turbidity*	NTU	-	-	0.1	
11.	Calcium*	mg/L	75	200		
12.	Magnesium*	Mg/L	30	100		
13.	Sulphate*	mg/L	200	400	4.728	
14.	Total Alkalinity	mg/L	200	600	200	
15.	Carbonate*	mg/L	-	-		
16.	Bicarbonate*	mg/L	-	-		
17.	Chloride*	mg/L	250	1000	50	

**Remarks:**

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. The Sample is collected by the client himself. As such the lab has no involvement in sample collection.

Reviewed By

**Chemist**  
**District lab Bhandara**

Authorised By

**(Junior Geologist)**





Certificate no-TC9620

**District Water Testing Laboratory**  
**Groundwater Surveys and Development Agency**  
**Senior Geologist Office, Bhandara**  
**TEST REPORT (DWTL/SG/BHN/FR/06)**



**TEST METHOD EMPLOYED**

Sr. No.	Test Parameter	Test Method
1.	Colour*	-
2.	Odour*	-
3.	Temperature*	-
4.	Turbidity*	-
5.	pH	APHA 23 <sup>RD</sup> EDN, METHOD 4500
6.	Electrical Conductivity	APHA 23 <sup>RD</sup> EDN, METHOD 2510B
7.	TDS	APHA 23 <sup>RD</sup> EDN, METHOD 2540C
8.	Total Hardness	APHA 23 <sup>RD</sup> EDN, METHOD 2340C
9.	Calcium*	APHA 23 <sup>RD</sup> EDN, METHOD 3500Ca-B
10.	Magnesium*	APHA 23 <sup>RD</sup> EDN, METHOD 4500
11.	Fluoride	APHA 23 <sup>RD</sup> EDN, METHOD 4500F-B
12.	Nitrate	APHA 23 <sup>RD</sup> EDN, METHOD 4500 No <sub>3</sub> -B
13.	Iron	APHA 23 <sup>RD</sup> EDN, METHOD 3500 Fe-B
14.	Sulphate*	APHA 23 <sup>RD</sup> EDN, METHOD 4500 SO <sub>4</sub> -B
15.	Total Alkalinity*	APHA 23 <sup>RD</sup> EDN, METHOD 2320B
16.	Carbonate*	APHA METHOD
17.	Bicarbonate*	APHA METHOD
18.	Chloride*	APHA 23 <sup>RD</sup> EDN, METHOD 4500Cl-B

**Sample Details**

Sr. No.	Sample Code	lab Ref. Number	Village	District	Taluka	Source	Source Location
1	S1	DWTL/GSDA/BHN/05/01/2023	Bhandara	Bhandara	Bhandara	Borewell	Dream Dale Public School, Sindhi colony road, Bhandara

  
(Junior Geologist)